SVGW
Association
for water, gas and district heating
Grütlistrasse 44
CH- 8027 Zürich

Certification body water

Certificate No.: 1808-6784

Certificate holder: KLINGER Turkey Esn. Bag. Elem. Tic. ve San. A.S. Ist. End.ve Tic. Serb. Bölge Subes Orhanli Mevkii 6. Sok. No: 111/6, TR-34957 Tuzla Istanbul

In accordance with our regulation ZW101 „general terms and conditions of the SVGW certification body water" the SVGW certify the following serial products:

Rubric: Corrugated full metal pipes

Denomination: Corrugated stainless steel tubes for heat storage tanks

Types: DN 32 MH 211K
DN 40 MH 211K

DN: 11/4", 11/2" PN: 10 tmax: 95 °C

Certification Standard: SVGW ZW119/2 (01/21)

Validity: 31.01.2030

Conditions (C) / Remarks (R):
None

The applicant is entitled to offer the above mentioned products as certificated by the SVGW and to use the above SVGW-conformity mark (publication in the list of certificates water).

accredited according to
SN EN ISO/IEC 17065

SVGW Association for water, gas and district heating
Certification body water

Javier Fernandez
Head

Zurich, 13.01.2025

KLINGER Turkey Esn. Bag. Elem. Tic. ve San. A.S. Ist. End.ve Tic. Serb. Bölge Subesi, Orhanli Mevkii 6. Sok. No: 111/6, TR-34957 Tuzla Istanbul

Rubric: Corrugated full metal pipes

Denomination: Corrugated stainless steel tubes for heat storage tanks

Types	DN	PN	C°	Acoustic group	Losses kWh/24 h / ErP Class	Content	Index	Metrology
DN 32 MH 211K	11/4"	10	95	-	-	-	-	-
DN 40 MH 211K	11/2"	10	95	-	-	-	-	-

SVGW
Fachverband
für Wasser, Gas und Wärme
Grütlistrasse 44
CH- 8027 Zürich

Zertifizierungsstelle Wasser

Zertifikat Nr.: 1808-6784

Zertifikatsinhaber: KLINGER Turkey Esn. Bag. Elem. Tic. ve San. A.S. Ist. End.ve Tic. Serb. Bölge Subes Orhanli Mevkii 6. Sok. No: 111/6, TR-34957 Tuzla Istanbul

Gestützt auf das Reglement ZW101 „Allgemeine Geschäftsbedingungen der SVGW Zertifizierungsstelle Wasser" zertifiziert der SVGW die folgenden Serienprodukte:

Rubrik: Flexible Wellrohrverbindungen

Bezeichnung: Edelstahlwellrohre für Wärmespeicher

Typen: DN 32 MH 211K
DN 40 MH 211K

DN: 11/4", 11/2" PN: 10 tmax: 95 °C

Zertifizierungsgrundlage: SVGW ZW119/2 (01/21)

Gültigkeit: 31.01.2030

Auflagen (A) / Bemerkungen (B):
Keine

Der Antragsteller ist berechtigt, die oben erwähnten Produkte als SVGW zertifiziert anzubieten und das obige SVGW-Konformitätszeichen zu verwenden (Publikation im Zertifizierungsverzeichnis Wasser).

akkreditiert nach
SN EN ISO/IEC 17065

SVGW Fachverband für Wasser, Gas und Wärme
Zertifizierungsstelle Wasser

Javier Fernandez
Leiter

Zürich, 13.01.2025

KLINGER Turkey Esn. Bag. Elem. Tic. ve San. A.S. Ist. End.ve Tic. Serb. Bölge Subesi, Orhanli Mevkii 6. Sok. No: 111/6, TR-34957 Tuzla Istanbul

Rubrik: Flexible Wellrohrverbindungen

Bezeichnung: Edelstahlwellrohre für Wärmespeicher

Typen	DN	PN	C°	Geräusch-gruppe	Verluste kWh/24 h / ErP Klasse	Inhalt	Index	Metrologie
DN 32 MH 211K	11/4"	10	95	-	-	-	-	-
DN 40 MH 211K	11/2"	10	95	-	-	-	-	-